



NOTES:

1. PVC SADDLE TEES SHALL NOT BE USED ON NEW CONSTRUCTION AND ARE ONLY ALLOWED ON EXISTING PVC, CLAY, IPS, CONCRETE, ASBESTOS CEMENT, AND PE PIPE.
2. PVC SADDLE TEE SHALL BE ASTM D-3034 SDR35.
3. PVC COMPOUNDS SHALL BE ASTM D1784 WITH CELL CLASS OF 12454-B/C OR 12364-C.
4. ALL ELASTOMERIC SEALS (RUBBER GASKETS) SHALL BE ASTM F477.
5. STAINLESS STEEL BANDS SHALL BE 300 SERIES, FULL 9/16" WIDTH BAND, 5/16" SHOULDERED HEX HEAD, SLOTTED SCREW AND IS CADMIUM PLATED, CARBON STEEL.
6. INSERTION HOLE SHALL BE CORE DRILLED AND LOCATED A MINIMUM 12" CLEAR DISTANCE FROM PIPE BELL.
7. PVC SADDLE SHALL NOT PROTRUDE BEYOND THE INSIDE WALL OF THE HOST PIPE.

PVC Saddle Gasket

CITY OF
WILSONVILLE



DRAWING NUMBER: S-2155

DRAWN BY: SR

SCALE: N.T.S.

FILE NAME: S-2155.DWG

APPROVED BY: NK

DATE: 6/4/14

PUBLIC WORKS STANDARDS